



ROOF PLAN

**EDGE CONDITION LEGEND**

- E1 - 5'-0" (H) WALL FLASHING, REMOVE ALL FLASHINGS INCLUDING LOW METAL COUNTER FLASHING. INSTALL MECH ATTACHED 1/2" DENS DECK OVER BUR FLASHING SUBSTRATE ONLY. FULLY ADHERE NEW WALL FLASHING FULL HEIGHT, INSTALL TERM BAR, SEALANT AND SURFACE MOUNTED COUNTER FLASHING WITH SEALANT JOINT TIGHT TO BOTTOM OF EIFS WALL CLADDING (SEE DET. 0001)
- E2 - 6'-0" (H) TO 9'-0" (H)(VARIES) X 2'-0" (W) PARAPET WALL. REMOVE EXISTING WALL FLASHINGS AND ANY LOW METAL COUNTER FLASHING. INSTALL MECH ATTACHED 1/2" DENS DECK OVER BUR FLASHING SUBSTRATE ONLY. INSTALL FULLY ADHERED WALL FLASHING FULL HEIGHT, INSTALL TERM BAR, SEALANT AND SURFACE MOUNTED COUNTER FLASHING WITH SEALANT JOINT TIGHT TO BOTTOM OF EIFS COPING (SEE DET. 0001). MAKE REPAIRS AND INSTALL ELASTOMERIC COATING ON TOP AND ROOF SIDE OF EIFS COPING
- E3 - 6'-0" (H) TO 9'-0" (H)(VARIES) X 1'-0" (W) PARAPET WALL. REMOVE EXISTING METAL COPING, WALL FLASHINGS AND ANY LOW METAL COUNTER FLASHING. INSTALL MECH ATTACHED 1/2" DENS DECK OVER BUR FLASHING SUBSTRATE ONLY. INSTALL FULLY ADHERED WALL FLASHING UP OVER EXIST. TOP PLATE AND DOWN FRONT FACE, INSTALL NEW TWO PIECE METAL FASCIA (SEE DET. 0002)

**PENETRATIONS LIST:**

- CURBS**  
 A - 7.5'X4.5' RTU  
 B - 24'X6' RTU  
 C - 6'X3.5' RTU  
 D - 3.5'X4' RTU  
 E - 8'X39' RTU  
 F - 10'X42' RTU

**PIPE PENETRATIONS**

- 1" - 7
- 2" - 3
- 3" - 5
- 4" - 4

- 6'X6' SAT DISH PAD - 1 (SET ON WALK PADS)
- 1'X1' GOOSENECK DUCT CURB - 1
- 2.5'X3' CONDENSER CURB - 1
- 3'X4' SAT DISH PAD - 1 (SET ON WALK PADS)
- 1'9"X1'9" GOOSENECK DUCT CURB - 1
- 8" ROUND VENT STACK - 2
- 1.5'X1.5' RTV - 4
- 2'X2' RTV - 4
- 6" ROUND VENT STACK - 4
- 1' ROUND UNIT STACK - 7
- 6'X6" PITCH BOXES FOR I-BEAM SUPPORT POSTS HOLDING UP LARGE EXHAUST FANS - 4
- 1'9"X1'9" RTV - 5
- 1'X1' SAT DISH PITCH BOX AROUND POLE - 1
- 6'X6" PITCH BOX - 2

General Notes



DISCLAIMER  
 ALL DESIGN, DESIGN ARRANGEMENTS, AND PLANS INDICATED OR REPRESENTED BY THIS DRAWING ARE OWNED BY AND ARE THE PROPERTY OF ROOFINGPROJECTS.COM AND WERE CREATED, EVOLVED AND DEVELOPED FOR USE ON AND IN CONNECTION WITH THE SPECIFIED PROJECT. NONE OF SUCH DESIGN, DESIGN ARRANGEMENTS OR PLANS SHALL BE LOANED BY OR DISCLOSED TO ANY THIRD PARTY WITHOUT THE WRITTEN PERMISSION OF ROOFINGPROJECTS.COM.

WRITTEN DIMENSIONS ON THIS DRAWING SHALL TAKE PRECEDENCE OVER SCALED DIMENSIONS. CONTRACTORS SHALL VERIFY AND BE RESPONSIBLE FOR ALL DIMENSIONS AND CONDITIONS ON THE JOB AND THIS OFFICE MUST BE NOTIFIED OF ANY VARIATIONS FROM THE DIMENSIONS AND CONDITIONS SHOWN BY THESE DRAWINGS.

No.	Revision/Issue	Date

Firm Name and Address  
 RoofingProjects-com  
 17 High Street  
 Suite 301  
 Norwalk, CT  
 06851

Project Name and Address  
 2025  
 Safeway #1579  
 19718 Germantown Rd  
 Germantown, MD 20874

Project	Sheet
Date May 7, 2025	1
Scale 1/16" = 1'-0"	