



NOTES:

1. VENT STACKS AND OTHER PIPES SHOULD HAVE A MINIMUM OF 12 INCHES OF CLEARANCE ON ALL SIDES FROM WALLS, CURBS, AND OTHER PROJECTIONS TO FACILITATE PROPER FLASHING.
2. REMOVE ALL EXISTING PIPE FLASHINGS

PROJECT TITLE :

ROOF RECOVERY

2025

LEDBETTER PROPERTIES
 HIGHLAND CROSSING SHOPPING CENTER
 91 HIGHLAND DRIVE
 ELLIJAY, GA

JOB NO,	
DRAWN BY :	
CHECKED	
SCALE	
DATE	April 18, 2025
CAD FILE	
SHEET	

DRAWING NO.

d008



PLUMBING VENT