



NOTES:

1. VENT STACKS AND OTHER PIPES SHOULD HAVE A MINIMUM OF 12 INCHES OF CLEARANCE ON ALL SIDES FROM WALLS, CURBS, AND OTHER PROJECTIONS TO FACILITATE PROPER FLASHING. (SEE TABLE 4.)
2. TOP LAYER OF INSULATION CAN BE EITHER THERMAL INSULATION OR COVERBOARD INSULATION.

PROJECT TITLE :

ROOF REPLACEMENT

2025

RADIANT PARTNERS

JC PENNY

3437 Masonic Drive

Alexandria, LA

JOB NO,

DRAWN BY :

CHECKED

SCALE

DATE

May 27, 2025

CAD FILE

SHEET

DRAWING NO.

d007



PLUMBING VENT