



NOTES:

1. VENT STACKS AND OTHER PIPES SHOULD HAVE A MINIMUM OF 12 INCHES OF CLEARANCE ON ALL SIDES FROM WALLS, CURBS, AND OTHER PROJECTIONS TO FACILITATE PROPER FLASHING. (SEE TABLE 4.)
2. TOP LAYER OF INSULATION CAN BE EITHER THERMAL INSULATION OR COVERBOARD INSULATION.

PROJECT TITLE :

ROOF RECOVERY

2026

RADIANT PARTNERS

SUNSET MALL

4001 SUNSET DR #1182

SAN ANGELO, TX 76904

JOB NO,

DRAWN BY :

CHECKED

SCALE

DATE

Jan 12, 2026

CAD FILE

SHEET

DRAWING NO.

d008



PLUMBING VENT